

48109 - 19 104109 - 07/02/024

Public Health Engineering Department

Monthly Water Quality Monitoring Report

District Name: - Valshall

Month:-Feb.- 2024

Format:

NOTE. *With the following Words Specimenation is now done.*

(a) Throughout any year, 95% of the samples should not contain *coliform* organisms in 100ml. **(b)** No sample should contain more than 10 *coliform* organisms per 100ml. **(c)** *Coliform* organisms should not be detected in 100ml of any two consecutive samples.

Lab. Assistant
PH Division Hajipur

~~02/02/2024~~

Chemist
PH Division Hajipur

4/07-02-29

PH Division Hajipur
Chemist